



सीएसआईआर - के० ख० एवं ई० अ० सं० परीक्षण प्रकोष्ठ

CSIR - CIMFR TESTING CELL

TEST CERTIFICATE / परीक्षण प्रमाण पत्र



अतिरिक्त प्रथम प्रति  
Additional First Copy

FORMAT NO.: (CIMFR: DQM: FLP02: F-01:REV-01)  
(Flameproof & Equipment Safety)

ID NO.: 55/16

CODE NO.: FLP/213/15-16

**CONCLUSION:** The above **FLAMEPROOF/WEATHERPROOF JUNCTION BOX**, in cast aluminium Alloy LM-6 construction designated by **Model No.: JB 2015**, meets the test requirements for flameproofness as per IS/IEC 60079-1:2007, general requirements as per IS/IEC 60079-0:2004 and for weatherproof (IP-66 degree) as per IS/IEC 60529:2001. Hence, the above mentioned apparatus may be used in Zone 1 & 2 and Gas Group: IIB atmosphere.

**Reported By**

*Navin Kumar*

(NAVIN KUMAR)  
Technical Officer

Dated: 19<sup>th</sup> September, 2016  
Flameproof & Equipment Safety  
Formerly: Flame & Explosion Laboratory  
Central Institute of Mining & Fuel Research, (CSIR)  
(Erstwhile: Central Mining Research Institute)  
Barwa Road, DHANBAD - 826 015,  
(JHARKHAND) INDIA

**Approved By**

*A. K. Singh*  
(A. K. SINGH) 19/09/16

Head  
Flameproof & Equipment Safety

*V. K. Singh* 23-9-16  
(V. K. SINGH)  
HORG