



सीएसआईआर - के० ख० एवं ई० अ० सं० परीक्षण प्रकोष्ठ

CSIR - CIMFR TESTING CELL

TEST CERTIFICATE / परीक्षण प्रमाण पत्र

अतिरिक्त प्रथम प्रति  
Additional First Copy

FORMAT NO.: (CIMFR: DOM: FLP02: F-01:REV-01)  
(Flameproof & Equipment Safety)

ID NO.: 55/16

CODE NO.: FLP/213/15-16

(ii) **Composition of the cast aluminum alloy LM-6 declared by the manufacturer:** Composition of cast aluminum alloy LM-6 purported to be forming the material of construction of the enclosure has been declared by the manufacturer in the drawing having Mg. 0.1% (max).

*However no sample of the alloy was drawn from the prototype enclosure for verifying its chemical composition declared by the manufacturer.*

**16. Documents/Samples Submitted :**

- i) Application form
- ii) Drawings
- iii) Prototype/test sample

**17. Compliance of prototype or sample with documents:** The test sample of electrical apparatus submitted for the type tests complies with the manufacturers documents referred above.

**Note:** CIMFR has however not checked and tested the compliance of the apparatus to any standard other than the above standards.

**SCOPE OF THE TEST CERTIFICATE**

The Test Certificate issued by CIMFR testifies that the apparatus has been found to comply with the definition of flameproof-weatherproof APPARATUS contained in the relevant Standard specifications. They do not vouch for the quality of the equipment in any other respect.

*This Institute reserves the right to review amend or withdraw this Test Report at any time if considered necessary in the interest of safety.*

*Naim Kumar*