



सीएसआईआर - के० ख० एवं ई० अ० सं० परीक्षण प्रकोष्ठ

CSIR - CIMFR TESTING CELL



TEST CERTIFICATE / परीक्षण प्रमाण पत्र

अतिरिक्त प्रथम प्रति  
Additional First Copy

ID Number: 250/ 16 Code Number: FLP/65/ 16

Test Date : 01/ 09 / 2016

Manufacturer Details : M/S KESKAMAT & COMPANY

Manufacturer Address : MUMBAI- 400 025

Model / Type : MODEL NO .: JB2016-IIC

Category No. : NA

Gas : ACETYLENE

Gas Group : IIC


Equipment Details : FLP/WP JUNCTION BOX

Enclosure Details : SINGLE ENCLOSURE

Serial / Badge No. : NA

Peak Pressure : 5.57 Bar at 35.64 ms

Explosion Pressure vs Time Graph



*Ricronishya*  
8.9.16  
(Testing Officer)

*[Signature]*  
(Discipline Head)