



सीएसआईआर - के० एच० एच० एच० सं० परीक्षण प्रकोष्ठ

CSIR - CIMFR TESTING CELL

TEST CERTIFICATE परीक्षण प्रमाण पत्र



ORIGINAL COPY

 FORMAT NO.: (CIMFR-DM: FLP02: F-01:REV-01)  
 (Flame & Explosion Laboratory)

ID NO.: 51/16

CODE NO. FLP/201/15-16

26.14	Charging test		NA
26.15	Measurement of Capacitance		NA
27	<b>Routine verification and tests</b>	Manufacturer's responsibility: Compliance to prototype of the product and physical measurement of gap and flamepath and hydraulic test at the pressure given in <b>Result#B2</b> for 1min. for every sample.	
28	Manufacturer's responsibility	Conformity of the apparatus to the applicable standards	<b>Complies</b>
29	Marking		<b>Ex d IIB IP-66</b>
30	Instructions	Instruction related to use, installation, maintenance, adjustment to be provided by the manufacturer along with the apparatus.	

\*\*\*\*\*