



सीएसआईआर - केंद्र खण एवं ईंधन अनुसंधान प्रयोगशाला परीक्षण प्रकोष्ठ

Continuation Sheet

CSIR - CIMFR TESTING CELL



TEST CERTIFICATE / परीक्षण प्रमाण पत्र ORIGINAL COPY

FORMAT NO.: (CIMFR: DQM: FLP02: F-01:REV-01)
(Flameproof & Equipment Safety)

ID NO.: 52/16

CODE NO. FLP/201A/15-16

CONCLUSION: The **FLAMEPROOF/WEATHERPROOF (IP-66) WELL GLASS LIGHTING FITTING**, in cast aluminium alloy LM-6 construction designated by **Model No.: KKWGLF/02, Cat. No.: KK/WGLF/07/03, Type No.: KK/FWGLF/02**, meets the test requirements for flameproofness as per IS/IEC 60079-1:2007 & general requirements as per IS/IEC 60079-0:2004. Hence, the above mentioned apparatus may be used in Zone 1 & 2 for Gas Group - IIB atmosphere.

Reported By

(R. K. MISHRA)

Sr. Technical Officer

Dated: 9th August, 2016

Flameproof & Equipment Safety

Formerly: Flame & Explosion Laboratory

CSIR - Central Institute of Mining & Fuel Research,

Barwa Road, DHANBAD - 826 015,

(JHARKHAND), INDIA

Approved By

(A. K. SINGH)
Head

Flameproof & Equipment Safety