

के० ख० एवं ई० सं० परीक्षण प्रमाण पत्र - CIMFR TESTING CELL  
सीएसआईआर-केन्द्रीय खनन एवं ईंधन अनुसंधान संस्थान  
(वैज्ञानिक तथा औद्योगिक अनुसंधान परिषद्)



ORIGINAL COPY

**CSIR - CENTRAL INSTITUTE OF MINING AND FUEL RESEARCH**

FORMERLY : CENTRAL MINING RESEARCH INSTITUTE  
( COUNCIL OF SCIENTIFIC & INDUSTRIAL RESEARCH )

बरवा रोड, धनबाद - 826015 (भारत) - BARWA ROAD, DHANBAD-826015 (INDIA)

**परीक्षण प्रमाण पत्र - TEST CERTIFICATE**

FORMAT NO.: (CIMFR: DQM: FLP02: F-01:REV-01)

(Flameproof & Equipment Safety)

Revalidation Report No.: CIMFR/TC/SR/ 436 Dated: 09 August, 2016

Equipment. ID NO. 52/16

Code No. FLP/201A/15-16

Application Ref. No.: KK/CIMFR/2015-16/02

Dated: 12/12/2015

1. Applicant : M/S. KESHKAMAT & COMPANY  
9/129, ADARSH NAGAR, PRABHADEVI,  
MUMBAI - 400 025
2. Manufacturer: Same as above
3. Apparatus : FLAMEPROOF/WEATHERPROOF (IP-66) WELL GLASS LIGHTING FITTING.
4. Designated by : Model No.: KKWGLF/02, Cat. No.: KK/WGLF/07/03, Type No.: KK/FWGLF/02
5. Gas Group, Zone : Zone 1 & 2 and Gas Group - IIA & IIB atmosphere.
6. Electrical ratings: Rated at 240V AC/DC, 400Watts (upto)
7. Temperature Class: Ref. test report no.: CIMFR/TC/P/H364, Dated: 10/08/2009
8. Degree of Ingress Protection: IP-66 (Ref. test report no.: CIMFR/TC/P/H364, Dated: 10/08/2009)
9. Material of Construction: Cast aluminium alloy LM-6 construction.
10. Description of the apparatus: FLAMEPROOF/WEATHERPROOF (IP-66) WELL GLASS LIGHTING FITTING.

A.

Description	Volume (in cc)		Min. Wall Thickness (in mm)	Nos. & Size of Bolts/Fasteners
	Gross	Net		
Well Glass Lighting Fitting	5000 cc	3000 cc	8mm	Threaded Joint.

*Rm*  
8.8.16